



Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII-Division 1



PTB-7-2014

CRITERIA FOR SHELL-AND-TUBE HEAT EXCHANGERS ACCORDING TO PART UHX OF ASME SECTION VIII DIVISION 1

Prepared by:

Francis Osweiler
OSWECONSULT





Date of Issuance: June 16, 2014

This document was prepared as an account of work sponsored by ASME Pressure Technology Codes and Standards (PTCS) through the ASME Standards Technology, LLC (ASME ST-LLC).

Neither ASME, the author, nor others involved in the preparation or review of this document, nor any of their respective employees, members or persons acting on their behalf, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe upon privately owned rights.

Reference herein to any specific commercial product, process or service by trade name, trademark, manufacturer or otherwise does not necessarily constitute or imply its endorsement, recommendation or favoring by ASME or others involved in the preparation or review of this document, or any agency thereof. The views and opinions of the authors, contributors and reviewers of the document expressed herein do not necessarily reflect those of ASME or others involved in the preparation or review of this document, or any agency thereof.

ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME is the registered trademark of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers

Two Park Avenue, New York, NY 10016-5990

ISBN No. 978-0-7918-6945-1

Copyright © 2014 by

THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS

All Rights Reserved

Printed in the U.S.A.



TABLE OF CONTENTS

Foreword..... x
 Abbreviations and Acronyms xi
PART 1 INTRODUCTION..... 1
 1 SCOPE..... 2
 2 HISTORICAL BACKGROUND 3
 3 TYPES OF HEAT EXCHANGERS COVERED 5
 4 TYPES OF TS CONFIGURATIONS 7
 5 LOADING CASES 9
 6 STRUCTURE OF PART UHX..... 10
 7 STRUCTURE OF THE DOCUMENT 11
 8 NOTATIONS 12
 References—Part 1 13

PART 2 TUBESHEET CHARACTERISTICS..... 14
 1 SCOPE (UHX-11.1) 15
 2 NOTATIONS 16
 3 DESIGN ASSUMPTIONS (UHX-11.2) 17
 4 LIGAMENT EFFICIENCIES (UHX-11.5.1) 18
 4.1 Introduction..... 18
 4.2 Historical Background 19
 4.3 LE in Part UHX (UHX-11.5.1)..... 20
 5 EFFECTIVE ELASTIC CONSTANTS (UHX-11.5.2) 25
 5.1 Introduction..... 25
 5.2 Historical Background 25
 5.3 The Square Pattern Problem 26
 5.4 Synthesis of Results 27
 5.5 Determination of EEC for the Full Range of μ^* ($0.1 \leq \mu^* \leq 1.0$)..... 27
 5.6 Determination of EECs for UHX Rules (UHX-11.5.2) 28
 5.7 Conclusion 28
 References—Part 2..... 32

PART 3 ANALYICAL TREATMENT OF FIXED TUBESHEET HEAT EXCHANGERS 33
 1 SCOPE (UHX-13.1) 34
 2 HISTORICAL BACKGROUND 35
 3 GENERAL 36
 3.1 TS Configurations (UHX-13.1) 36
 3.2 Notations (UHX-13.3) 37
 3.3 Loading Cases (UHX-13.4) 40
 3.4 Design Assumptions (UHX-13.2)..... 41
 3.5 Basis of Analytical Treatment 42
 3.5.1 General..... 42
 3.5.2 Free Body Diagram..... 43
 4 AXIAL DISPLACEMENTS AND FORCES ACTING ON THE TUBES AND ON THE SHELL... 45
 4.1 Axial Displacement and Force Acting on the Tubes (Figure 18) 45
 4.2 Axial Displacement and Force Acting on the Shell 46
 5 DEFLECTION AND LOADS ACTING ON THE TUBESHEET 48



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
 Division 1

5.1	Equivalent Plate Resting on an Elastic Foundation	48
5.2	Determination of Integration Constants A and B	51
5.3	Deflection.....	53
5.4	Net Effective Pressure	53
5.5	Rotation	53
5.6	Shear Force	54
5.7	Bending Moment	55
5.8	Conclusion.....	55
6	TREATMENT OF THE UNPERFORATED RIM.....	56
6.1	Edge Loads Applied on Shell and Channel at their Connection to the TS	56
6.2	Equilibrium of the Unperforated Rim.....	58
6.3	Edge Loads V_a and M_a Applied to the Tubesheet.....	61
7	EQUIVALENT PRESSURE ACTING ON TUBESHEET	64
7.1	Definition	64
7.2	Determination of P_e	65
8	STRESSES IN THE HEAT-EXCHANGER COMPONENTS	68
8.1	TS Net Effective Pressure.....	68
8.2	TS Axial Displacement	68
8.3	TS Rotation.....	69
8.4	Stresses in the Tubesheet	69
8.5	Axial Membrane Stress in Tubes.....	72
8.6	Stresses in the Shell	74
8.7	Stresses in the Channel	76
9	DETERMINATION OF THE ALLOWABLE STRESS LIMITS.....	78
9.1	General Considerations.....	78
9.2	Allowable Stress Limit in the Tubesheet	79
9.3	Allowable Stress Limit in the Tubes.....	79
9.4	Allowable Membrane Stress Limit in the Shell	79
9.5	Allowable Membrane + Bending Stress Limit in the Shell	79
9.6	Allowable Membrane + Bending Stress Limit in the Channel	79
9.7	Conclusions.....	80
10	ADDITIONAL RULES	81
10.1	Effect of Different Shell Thickness and Material Adjacent to the TS (UHX-13.6).....	81
10.2	Effect of Plasticity at Tubesheet-Shell-Channel Joint (UHX-13.7)	82
10.3	Effect of Radial Thermal Expansion Adjacent to the Tubesheet (UHX-13.8).....	84
10.4	Calculation Procedure for Simply Supported Tubesheets (UHX-13.9)	87
10.5	Tubesheet Effective Bolt Load (UHX-8)	87
10.6	Tubesheet Flange Extension (UHX-9).....	88
10.7	HE Set-up with a Thin-Walled Expansion Joint (UHX-13.16).....	90
10.8	HE Set-up with a Thick-Walled Expansion Joint (UHX-13.17).....	90
11	HOW TO USE THE RULES	92



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
 Division 1

12	CHECKING OF THE RESULTS	93
12.1	Comparison with FEA.....	93
12.2	Comparison with CODAP French Rules.....	95
12.3	Comparison with TEMA Rules.....	99
12.4	Comparison with Circular Plates Subject to Pressure	105
12.5	Conclusions.....	108
	References—Part 3.....	109
PART 4 FLOATING TUBESHEETS.....		110
1	SCOPE.....	111
2	HISTORICAL BACKGROUND	112
3	GENERAL	113
3.1	TS Configurations (UHX-14.1)	113
3.2	Notations.....	114
3.3	Loading Cases (UHX-14.4)	117
3.4	Design Assumptions (UHX-14.2).....	118
3.5	Basis of Analytical Treatment	119
3.5.1	General.....	119
3.5.2	Free Body Diagram for ST TS.....	120
3.5.3	Free Body Diagram for FL TS.....	121
4	AXIAL DISPLACEMENTS AND FORCES ACTING ON THE TUBES AND ON THE SHELL.....	123
4.1	Axial Displacement and Force Acting on the Tubes (Figure 42)	123
4.2	Axial Displacement and Force Acting on the Shell (Figure 43).....	124
5	DEFLECTION AND LOADS ACTING ON THE TUBESHEET	125
5.1	Equivalent Plate Resting on an Elastic Foundation (Figure 44)	125
5.2	Determination of Integration Constants A and B.....	126
6	TREATMENT OF THE UNPERFORATED RIM.....	127
6.1	Edge Loads Applied on Shell and Channel at their Connection to the TS	127
6.2	Equilibrium of the Unperforated Rim.....	127
6.2.1	Due to Axial Loads.....	127
6.2.2	Due to Applied Moments.....	133
6.2.3	Edge Loads V_a and M_a Applied to the Tubesheet	133
7	EQUIVALENT PRESSURE ACTING ON THE TUBESHEET	134
8	STRESSES IN THE HEAT-EXCHANGER COMPONENTS	135
9	DETERMINATION OF ALLOWABLE STRESS LIMITS	136
10	ADDITIONAL RULES	137
11	HOW TO USE THE RULES	138
11.1	Stationary TS.....	138
11.2	Floating TS.....	138
11.3	Calculation Procedure	138
11.4	Calculation Using a Fixed TS HE Software.....	139
	References—Part 4.....	140
PART 5 ANALYTICAL TREATMENT OF U-TUBE TUBESHEET HEAT EXCHANGERS		141
1	SCOPE.....	142
2	HISTORICAL BACKGROUND	143



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
 Division 1

3	GENERAL	144
3.1	TS Configurations (UHX-12.1)	144
3.2	Notations	144
3.3	Loading Cases (UHX-12.4)	146
3.4	Design Assumptions (UHX-12.2).....	147
3.5	Basis of Analytical Treatment	147
3.5.1	General.....	147
3.5.2	Free Body Diagram.....	148
4	TREATMENT OF THE PERFORATED TUBESHEET	150
5	TREATMENT OF THE UNPERFORATED RIM	151
5.1	Edge Loads Applied on Shell and Channel at their Connection to the TS	151
5.2	Equilibrium of the Unperforated Solid Rim	151
6	STRESSES IN THE HEAT-EXCHANGER COMPONENTS	156
6.1	Stresses in the Tubesheet	156
6.2	Stresses in the Shell and Channel	156
6.3	Determination of Stresses using the Fixed TS Rules	157
7	DETERMINATION OF THE ALLOWABLE STRESS LIMITS.....	158
8	ADDITIONAL RULES	159
8.1	Effect of Plasticity at the Tubesheet-Shell-Channel Joint (UHX-12.5).....	159
9	HOW TO USE THE RULES	160
10	COMPARISON WITH TEMA RULES	161
10.1	TEMA Formula.....	161
10.2	Numerical Comparisons.....	161
	References—Part 5.....	163
	PART 6 SUMMARY AND CONCLUSIONS	164
1	SUMMARY AND CONCLUSIONS	165
	Annex A — Values of Effective Elastic Constants from Various Authors	168
	Annex B — Values of Effective Elastic Constants for the Full Range of μ ($0.1 \leq \mu \leq 1.0$)	170
1	Introduction.....	170
2	Curves (From [13])	170
3	Numerical Values (From [13]).....	171
4	Polynomials	176
	Annex C — Poisson’s Ratio in Tubes and Shell	177
	Annex D — Shell Pressure Acting on the Expansion Joint Sidewalls	179
	Annex E — Differential Pressure Acting on the Equivalent Solid Plate	180
	Annex F — Solution of Differential Equation $w(x)$	182
	Annex G — Coefficients $Z_d, Z_v, Z_w, Z_m; Q_m, Q_v; Q_\alpha, Q_\beta; F_m, F_t$	184
	Annex H — Radial Displacement and Rotation of the Shell at its Connection with the Ring	189
1	Radial Displacement Due to Internal Pressure P_s	189
2	Radial Displacement and Rotation Due to Edge Loads Q_s and M_s	190
3	Radial Displacement Due to Internal Pressure and Edge Loads	190
4	Channel.....	190
	Annex I — Shell-to-Ring Connection in Radial Direction	191



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
 Division 1

Annex J — Minimum Length of Shell and Channel when Integral with the TS 193
 Annex K — Formulas for a Hemispherical Channel when Integral with the TS 195
 1 Radial Displacement Due to Internal Pressure P_c 195
 2 Radial Displacement and Rotation Due to Edge Loads Q_s and M_s 195
 3 Radial Displacement Due to Internal Pressure and Edge Loads 196
 Annex L — Equilibrium of Ring Subjected to Edge Moments 197
 Annex M — Direct Determination of the Equivalent Pressure 204
 Annex N — Formulas To Be Used When $P_e=0$ 208
 1 Net Effective Pressure: $q(x)$ 208
 2 Axial Displacement: $w(x)$ 208
 3 Rotation: $\theta(x)$ 208
 4 Bending Stress: $\sigma(x)$ 208
 5 Shear Stress: $\tau(x)$ 209
 6 Axial Stress in Tubes: $\sigma_t(x)$ 209
 Annex O — Tabular and Graphical Representation of Coefficient $F_t(x)$ 210
 Annex P — Tabular and Graphical Representation of Coefficient $F_m(x)$ 227
 Annex Q — Tabular and Graphical Representation of Coefficient $F_Q(x)$ 238
 Annex R — Determination of the Allowable Buckling Stress Limits 250
 Annex S — Common Intersection of Curves $\sigma_t(x)$ 254
 1 General 254
 2 Determination of Common Intersection x_o for $\sigma_t(x)$ 254
 3 Generalization to Other Stresses 255
 Annex T — Determination of Stresses in U-Tube TS HEs Using the Fixed TS Rules 256
 Annex U — Calculation of a U-Tube TS Using Floating or Fixed TS HE Software 259

MATHCAD EXAMPLES

Annex V — UHX-13 – Example E4.18.7 (PTB-4 2013 Edition) with General Equations 260
 Annex W — UHX-14 – Example E4.18.8 (PTB-4 2013 Edition) Stationary 306
 Annex X — UHX-14 – Example E4.18.8 (PTB-4 2013 Edition) Floating 335
 Annex Y — UHX-12 – Example E4.18.4 (PTB-4 2013 Edition) 364

LIST OF TABLES

Table 1 — Values for E^*/E and ν^* for Triangular Pattern from Meijers [12] 26
 Table 2 — Values of E^*/E and ν^* for Square Pattern in Pitch and Diagonal Directions from Slot and O'Donnell [7] 27
 Table 3 — Comparison of TEMA and ASME TS Thicknesses for 4 U-tube HEs 162
 Table 4 — Comparison of Effective Elastic Constants E^* and ν^* Values by Various Theoretical Methods for Plane Stress Problem 168
 Table 5 — Values of Curves ν^* as a Function of μ^* for Ratios $h/p=0.1, 0.15, 0.25, 0.5, 1.0$ and 2.0 for Triangular Pattern 172
 Table 6 — Values of Curves ν^* as a Function of μ^* for Ratios $h/p=0.1, 0.15, 0.25, 0.5, 1.0$ and 2.0 for Square Pattern 173

LIST OF FIGURES

Figure 1 — Three Types of Tubesheet Heat Exchangers 6
 Figure 2 — Tubesheet Configurations 8



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
 Division 1

Figure 3 — Ligament Area in the Actual Tubesheet	18
Figure 4 — Ligament Orientation in the Actual Tubesheet.....	19
Figure 5 — Ligament Efficiency Used in TEMA.....	20
Figure 6 — TS Equivalent Diameter D_o	20
Figure 7 — TS with Unperforated Lanes.....	22
Figure 8 — Tube Expansion Depth Ratio $\rho=l_{t,x}/h$	22
Figure 9 — Pass Partition Groove on Tubeside of the TS.....	24
Figure 10 — Pitch and Diagonal Directions for Square Pattern.....	26
Figure 11 — Curves and Tables for the Determination of E^*/E and ν^* (Triangular Pattern).....	29
Figure 12 — Curves and Tables for the Determination of E^*/E and ν^* (Square Pattern).....	30
Figure 13 — Curves E^*/E for Square Pattern Obtained from Polynomial Approximation Given in Figure 12	31
Figure 14 — Fixed Tubesheet Heat Exchanger	34
Figure 15 — Tubesheet Configurations.....	36
Figure 16 — Analytical Model Used in Design Method	43
Figure 17 — Free Body Diagram of the Analytical Model	44
Figure 18 — Axial Displacement of Tubes	45
Figure 19 — Axial Displacement of the Shell.....	46
Figure 20 — Loads Acting on the TS.....	48
Figure 21 —TS Displacement.....	49
Figure 22 —TS Displacement of the Unperforated Ring and Connection to Shell	52
Figure 23 — Ring Equilibrium of the TS	58
Figure 24 — Equivalent Pressure and Axial Force Acting on Plate.....	64
Figure 25 — Bending Stress Distribution Throughout the TS for $Q_3=0.0$ and $X_a=1, 3, 5, 7, 10$ and 15 ..	71
Figure 26 — Shell with Increased Thickness Adjacent to TSs.....	81
Figure 27 — Temperature Gradient at TS-Shell-Channel Joint	85
Figure 28 — Tubesheet Flanged Extension.....	89
Figure 29 — Minimum Required Thickness of the Tubesheet Flanged Extension	90
Figure 30 — Comparison of Tube Stresses Calculated Per UHX and FEA (Example E4.18.7).....	94
Figure 31 — Tube Stress Distribution Obtained by UHX, CODAP and FEA throughout the TS from $r = 0$ to $r = a_o$	99
Figure 32 — TEMA and ASME-CODAP Coefficient F for X Varying from $X=0$ to $X=20$	101
Figure 33 — TEMA Coefficient F	101
Figure 34 — TEMA Design Range	101
Figure 35 — Coefficient F_q as a Function of X for SS and CL TS	104
Figure 36 — Floating Tubesheet Heat Exchangers	111
Figure 37 — Stationary Tubesheet Configurations	113
Figure 38 — Floating Tubesheet Configurations.....	114
Figure 39 — Analytical Model Used in Design Method	120
Figure 40 — Free Body Diagram of the Analytical Model for the ST TS	121
Figure 41 — Free Body Diagram of the Analytical Model for the FL TS	122
Figure 42 — Axial Displacement of Tubes	123
Figure 43 — Axial displacement of the Shell.....	124
Figure 44 — Loads Acting on TS.....	125
Figure 45 — TS Displacement.....	126
Figure 46 — Ring Equilibrium of the ST TS.....	127
Figure 47 — Ring Equilibrium of the FL TS.....	128
Figure 48 — Immersed Floating TS HE.....	130
Figure 49 — Externally Sealed Floating TS HE.....	131
Figure 50 — Internally Sealed Floating TS HE.....	132
Figure 51 — U-tube Tubesheet Heat Exchangers.....	142



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
 Division 1

Figure 52 — TS Configurations 144
 Figure 53 — Free Body Diagram of the Analytical Model for the TS 149
 Figure 54 — Ring Equilibrium of the TS 152
 Figure 55 — Synthesis of E^*/E and ν^* Values from [1], Provided by Various Authors for Triangular and Square Pattern 169
 Figure 56 — Curves of Effective Elastic Constants for the Full Range of μ^* ($0.1 \leq \mu^* \leq 1.0$) 170
 Figure 57 — Radial Displacement due to Internal Pressure 189
 Figure 58 — Radial Force at Tubesheet Periphery 191
 Figure 59 — Ring Radial Displacement 191
 Figure 60 — Hemispherical Head 195
 Figure 61 — Configuration a 197
 Figure 62 — Configuration b 199
 Figure 63 — Configuration c 201
 Figure 64 — Configuration d 201
 Figure 65 — Pressures P_s and P_t Acting on TS 204
 Figure 66 — Pressure P_s Acting on Bellows Joint 205
 Figure 67 — Effect of ν_t Due to Pressures P_s and P_t 205
 Figure 68 — Pressure P_t Acting on the Channel Head 206
 Figure 69 — Tube Buckling 251
 Figure 70 — Determination of Buckling Safety Factor, FS 253
 Figure 71 — Graphs Giving $\sigma_t(x)$ and $F_t(x)$ for the 7 Loading Cases (ASME 2013) 254



FOREWORD

The purpose of this document is to justify and provide technical criteria for the rules of Part Unfired Heat Exchanger (UHX) of ASME Section VIII Division 1, 2013 Edition, devoted to the design of U-tube, Fixed and Floating head Tubesheet Heat Exchangers. The criteria document applies also to Paragraph 4.18 of Section VIII, Division 2, 2013 Edition, which is entirely based on Part UHX.

Confirmation and documentation of the basis for UHX-rules is important for the members of the ASME Subgroup on Heat Transfer Equipment to use as a future reference, for confirmation or comparisons of code requirements, and for code development. It will be a valuable reference for both early career and experienced engineers who are using the UHX rules and may become involved in code development of such rules in the future.

The analytical treatment of the fixed tubesheet heat exchangers is based on classical discontinuity analysis methods to determine the moments and forces that the tubesheet, tubes, shell and channel must resist. The treatment provides, at any radius of the perforated tubesheet, the deflection, the rotation, the bending and shear stresses and the axial stress in the tubes. A parametric study permits one to determine the maximum stresses in the tubesheet and in the tubes which are given in UHX-13. The Floating Tubesheet and U-tube Tubesheet heat exchangers are treated as simplified cases of fixed tubesheet heat exchangers. A check of the results obtained is provided by comparing Finite Element Analysis (FEA) results, Tubular Exchanger Manufacturers Association (TEMA) results, and the French pressure vessel code Code Français de Construction des Appareils à Pression (CODAP). Applying the appropriate simplifications, the classical formulas for circular plates subjected to pressure, have been obtained.

The author thanks the members of the peer review committee who sent many valuable comments and provided helpful consulting in the development of this Criteria Document. In particular Ramsey Mahadeen for his support and detailed reviews, Urey Miller for his help in stress classification considerations, Tony Norton for his comments on theoretical issues and performing FEA calculations, Guido Karcher for his support, Anne Chaudouet who spent so much time for checking the development of the formulas and Gabriel Auriolles who supplied the raw Excel spreadsheets and graphs for analysis and was very helpful for computer issues.

The author acknowledges Centre Technique des Industries Mécaniques (CETIM) for its support in the development of the Criteria Document appearing in PART 3, dedicated to fixed tubesheet heat exchangers. The author further acknowledges, with deep appreciation, the activities of ASME ST-LLC and ASME staff and volunteers who have provided valuable technical input, advice and assistance with review and editing of, and commenting on this document.

Established in 1880, the American Society of Mechanical Engineers (ASME) is a professional not-for-profit organization with more than 130,000 members and volunteers promoting the art, science and practice of mechanical and multidisciplinary engineering and allied sciences. ASME develops codes and standards that enhance public safety, and provides lifelong learning and technical exchange opportunities benefiting the engineering and technology community. Visit www.asme.org for more information.



ABBREVIATIONS AND ACRONYMS

ASME	American Society of Mechanical Engineers
CL	Clamped
EEC	Effective Elastic Constants
FEA	Finite Element Analysis
FL	Floating
HEs	Heat Exchanger(s)
LE	Ligament Efficiency
SG-HTE	Subgroup on Heat Transfer Equipment
SS	Simply Supported
ST	Stationary
TEMA	Tubular Exchanger Manufacturers Association
TSs	Tubesheet(s)
UHX	Unfired Heat Exchanger



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
Division 1

INTENTIONALLY LEFT BLANK



PART 1

INTRODUCTION



PTB-7-2014: Criteria for Shell-and-Tube Heat Exchangers According to Part UHX of ASME Section VIII
Division 1

1 SCOPE

This criteria document covers the development of the tubesheet (TS) design rules for the U-tube, Fixed, and Floating Head TS Heat Exchangers (HE) configurations contained in Part UHX of Section VIII Division 1, 2013 Edition. It applies also to Paragraph 4.18 of Section VIII, Division 2 which is entirely based on Part UHX.

The free body diagram of the HE, the equilibrium and compatibility equations, the solution of resulting differential equations and all intermediate steps are provided to show the derivation of:

- the deflection and the rotation at any radius of the TS,
- the bending and shear stress at any radius of the TS,
- the axial stresses in the tubes at any radius of the TS,
- the axial stretch force acting in the shell,
- the axial displacement of the shell.

The document provides the technical basis of the following items:

- the required loading case combinations,
- the acceptance criteria for each TS configuration, as applicable,
- the TS characteristics including the Effective Elastic Constants,
- the TS extended as a flange.

The following effects are in addition to the above basic items:

- the effect of different shell material or thickness adjacent to the TS,
- the effect of plasticity at TS-shell-channel joint,
- the effect of radial differential thermal expansion between the TS and integral shell and channel,
- the tubesheet calculated as a simply supported TS.